

試驗報告



報告編號：HB-20-09449

C-20-38001

頁數：1 OF 2

報告日期：109年12月18日

委託單位：泰聯企業有限公司
 委託單位地址：新北市三重區光復路2段88巷30號
 樣品名稱：陶熙™綠色環保多用途矽酮密封膠
 型號：GREEN
 用量：塗刷1道總量：400 g/m²
 送驗人員：泰聯企業有限公司(李國銘)
 收件日期：109年11月20日
 試驗日期：109年11月27日~109年12月15日
 備註：1. 以上資料由顧客提供(收件及試驗日期除外)
 2. 除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製
 3. 下述報告內容標示#處由顧客提供

=====
 試驗結果：

試驗項目	CAS NO.	試驗方法	試驗結果		定量極限	單位
			0-1 小時	46-48 小時		
TVOC	---	本測試依據 ASTM D5116-17, 及內政部建築研究所, "室內建材揮發性有機逸散物質檢測標準試驗方法及程序之研究", 計畫編號：MOIS901014 方法檢測。	0.0274	0.0130	0.005	mg/m ² · hr

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

試驗報告



報告編號：HB-20-09449

C-20-38001

頁數：2 OF 2

報告日期：109年12月18日

試驗結果：

試驗項目	CAS NO.	試驗方法	試驗結果		定量極限	單位
			0-2 小時	44~48 小時		
甲醛	50-00-0	本測試依據 ISO 16000-9:2006 以及 ISO 16000-3:2011 方法檢測。	0.0167	N. D.	0.005	mg/m ² · hr

- 註：1. 若該測試項目屬於定量分析則以「定量極限」表示；
 若該測試項目屬於定性分析則以「偵測極限」表示。
 2. 低於定量極限/偵測極限之測定值以 "N. D." 表示。
 3. 本試驗轉件至 SGS 超微量工業安全實驗室-台北執行
 #4.

「健康綠建材標章」分級制度說明		
逸散分級	逸散速率 (mg/m ² · hr)	
	TVOC	甲醛
1 級	≤ 0.005	≤ 0.005
2 級	0.005 < TVOC ≤ 0.06	0.005 < 甲醛 ≤ 0.02
3 級	0.06 < TVOC ≤ 0.19	0.02 < 甲醛 ≤ 0.05

「健康綠建材標章」逸散分級判定			
甲醛 逸散分級 \ TVOC 逸散分級	1 級	2 級	3 級
1 級	E1	E2	E3
2 級	E2	E2	E3
3 級	E3	E3	E3

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.